

DEPARTMENT OF THE NAVY U.S. NAVAL AIR FACILITY ATSUGI PSC 477 BOX 9 FPO AP 96306-0001

11000 Ser N4-PRA4/0156 **0 4 OCT 2024**

From: Commanding Officer, U.S. Naval Air Facility Atsugi To: Parents and Staff

Subj: CHILD DEVELOPMENT CENTER, YOUTH CENTER, AND TEEN CENTER DRINKING WATER

Ref: (a) CNICINST 5090.6A

Encl: (1) Overview of Results and Actions

(2) Initial Sampling Results

(3) Floor Plans of the CDC, Youth and Teen Center

1. In my earlier letter announcing our Lead in Priority Areas (LIPA) drinking water testing program, I informed you we would be testing all water outlets at the Child Development Center (CDC), Youth Center, and Teen Center that could potentially be used for cooking, washing, or drinking. We collected and tested 118 samples from the facilities through which we identified two outlets at the CDC that exceeded 10 parts per billion (ppb) screening level for lead. This is the Navy's designated level for taking action with additional testing and corrective measures. The one outlet was a faucet in Room 117 and the other was a hallway water fountain adjacent to Room 142, both in building 3250. As a result, the two outlets were immediately secured to prevent use and corrective measures and flushing were implemented, in accordance with reference (a).

2. We completed the corrective measures and flushing and additional testing shows that all outlets are now below the screening level of 10 ppb. Specifically, the corrective actions taken included cleaning the faucet aerator and flushing the water fountain system.

3. I have attached the details of the corrective measures and re-testing for the two outlets that initially exceed the screening level in enclosure (1). Full initial testing results are included in enclosure (2). Enclosure (3) shows the floor plans with identification makers for where the initial sampling was collected and highlighted locations of the exceedances.

4. For your information, I am also including the following links to additional drinking water quality resources:

a. Environmental Protection Agency (EPA) (lead in drinking water in schools and childcare centers): <u>https://www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water.</u>

Subj: CHILD DEVELOPMENT CENTER, YOUTH CENTER, AND TEEN CENTER DRINKING WATER

b. Annual water quality report for the installation: <u>https://cnrj.cnic.navy.mil/Operations-and-Management/Water-Quality-Information/Water-quality-reports/</u>.

5. If you have any health related questions or concerns about lead exposure, you are encouraged to contact your health care provider, or if you are a TRICARE beneficiary, please call the Primary Care appointment line at DSN (315) 264-3958/3959, or commercially at 011-81-46-763-3958/3959.

6. I am fully committed to the safety and health of all personnel and family members using our facilities. Rest assured that my team and I will continue to monitor and test the water quality at U.S. Naval Air Facility Atsugi to ensure our drinking water complies with EPA regulations. If you have any questions or concerns, please bring them to the attention of the staff. For specific questions regarding the sampling program, please contact the NAF Atsugi Public Affairs Office at DSN (315) 264-4452, or commercially at 011-81-46-763-4452.

N. B. LECLERC

Copy to: CNIC N45 NAVFAC Environmental (EV)

OVERVIEW OF RESULTS & ACTIONS



Enclosure (1)

Overview of Testing Results for Lead in Drinking Water and Corrective Actions for U.S. Naval Air Facility Atsugi (NAFA), Child Development Center (Building *3250*)

The Navy is committed to maintaining safe drinking water on its installations. Water supplied to the Navy and the Navy's water distribution system is regularly tested in compliance with the Safe Drinking Water Act. Because lead exposure is a particular concern for children, and lead may be in drinking water due to its presence in pipes, fittings, solder, and fixtures inside a building, Navy policy requires that we test the drinking water lead content in priority areas such as the youth center (YC), the teen center (TC), the child development centers (CDC) and the school every five years.

Navy environmental personnel conducted lead testing at the child development center, youth and teen center in accordance with Navy and Environmental Protection Agency (EPA) guidelines. Samples from various locations in the school were sent to a Navy Water Quality Oversight Council validated laboratory for analysis.

At the CDC, YC, and TC, outlets used for drinking, cooking, and washing were tested. Out of 118 samples collected, two (2) water outlets initially tested above the Navy screening level of 10 parts per billion (ppb) for lead in drinking water in the CDC. The outlets were secured and temporarily removed from service.

One (1) outlet that exceeded the screening level of 10 ppb was a faucet for handwashing in Youth Sport room 117 at the CDC building 3250, which tested at 11 ppb. Follow-up confirmation sampling at this outlet was conducted after removing and cleaning the faucet aerators. A faucet aerator is often found at the tip of modern indoor water faucets. Without an aerator, water usually flows out of a faucet as one big stream. An aerator spreads this stream into many little droplets, which helps save water, provides more uniform flow, and reduces splashing. However, the aerator and screen can trap debris which can accumulate lead.



After removing and cleaning the aerator, retesting showed that the water from the faucet in Youth Sport room 117 is below the screening level. The outlet will return back to service. A flushing and aerator cleaning program will be implemented in an effort to prevent potential lead leaching into the water.

One (1) water fountain exceeded the screening level of 10 ppb located at a hallway by room 142 at the CDC building 3250, which tested 47 ppb. In accordance with Commander, Navy Installations

Command (CNIC) Instruction 5090.6A, the affected water fountain was flushed and resampled. Follow-up confirmation sampling indicates that lead concentration in the water from the fountain is below the screening level after flushing, and therefore the water fountain will return back to service. A flushing program will be implemented in an effort to prevent potential lead leaching into the water.

A detailed summary of the results and corrective actions are provided in the next page.

A copy of all test results is included in enclosure 2, as well as the floor plans of the CDC, YC, and TC to show the locations of outlets that were tested and for the outlets that exceeded 10 ppb in enclosure 3.

Lead in Priority Areas (LIPA) and Corrective Actions NAFA Child Development Center Bldg. 3250

	SAMPLIN	G LOCATION DESCRIPTION			L SAMPLING F			AMPLING RES		CORRECTIVE ACTIONS
CATEGORY	SAMPLE ID	Outlet Location	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Water Fountain/Chiller 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	Description
SAMPLING DATE RESULTS DATE				7/27/2024			8/27/2024 9/11/2024	8/27/2024	8/27/2024	
DRINKING	3250-0142-CO- 01	Building 3250 - Child Development Center, Hallway 142, Cooler	Water Fountain	8/23/2024 47	YES	8/21/2024	Non-Detect	<u>9/11/2024</u> Non-Detect	9/11/2024 Non-Detect	Follow-up testing was conducted after flushi occurred at the water fountain with lead leve higher screening level. Since the follow-up results showed levels below screening level water fountain will return back to service. A flushing program will be implemented in ar effort to prevent potential lead leaching into the water.
COOKING	N/A	N/A	N/A		NO	N/A	N/A	N/A	N/A	N/A
WASHING	3250-0117-FA-03	Building 3250 - Child Development Center, Youth Sport Classroom 117, Faucet 3	Faucet	11	YES	8/21/2024	N/A	4.8	0.5	Follow-up testing was conducted after an aerator was cleaned at the faucet with lead level higher screening level. Since the follow- results showed levels below screening level faucet wil return back to service. A flushing a aerator cleaning program will be implemente in an effort to prevent potential lead leachin into the water.

¹ Affected outlets were immediately secured after receiving preliminary results/verbal communication from the lab on results exceeding the recommended level of 10 ppb.

Enclosure (1)

COMPLETE TEST RESULTS



Initial Sampling Results

Contract No: N40084-20-D-0051

Chugai Technos Test Report

Call No.2024-630D

Sampling Location / Name: NAF Atsugi: DW Monitoring (LIPA, JULY 2024)

NAF, ATSUGI, ENV

Report Issue Date:

23 Aug 2024

Chugai Technos Corporation

2-2-16 Ohnodai Midori-ku, Chiba 267-0056, Japan Tel: +81-43-295-1101 Fax: +81-43-295-2217 Kiyomi Noriyuki Manager

X. nonget.

SAMPLE SUMMARY DATA SHEET (1/24)

Analyte: Lead / Test Method: EPA200.8 / Sample Matrix: Drinking Water

QL: 0.0005 mg/L

Building Number / Floor :	Dullainį	g 280 - Youth	Center		Sampling	g		o.2024-630E Screening
Room Name	Room #	Outlet Type	Sample ID#	Date	Time	Collected by	Results (mg/L)	Level (mg/L)
Drinking Fountain	N/A	Main Office Fountain	0286-M001-CO-01	27-Jul-24	6:40	H.Namiki	0.0012	0.010
Bathroom Sink	N/A	sink	0286-M001-FA-01	27-Jul-24	6:40	H.Namiki	N.D.	0.010
Kitchen	N/A	Faucet	0286-K001-FA-01	27-Jul-24	6:45	H.Namiki	N.D.	0.010
Kitchen	N/A	Faucet	0286-K001-FA-02	27-Jul-24	6:45	H.Namiki	N.D.	0.010
Kitchen	N/A	Faucet	0286-K001-FA-03	27-Jul-24	6:45	H.Namiki	N.D.	0.010
Classroom 1	1	Faucet	0286-C001-FA-01	27-Jul-24	6:42	H.Namiki	0.0007	0.010
Classroom 1	1	Water Cooler	0286-C001-CO-01	27-Jul-24	6:42	H.Namiki	0.0006	0.010
Bathroom	1	Faucet	0286-C001-FA-02	27-Jul-24	6:42	H.Namiki	N.D.	0.010
Classroom 3	3	Faucet	0286-C003-FA-01	27-Jul-24	6:43	H.Namiki	N.D.	0.010
Classroom 3	3	Water Cooler	0286-C003-CO-01	27-Jul-24	6:43	H.Namiki	N.D.	0.010
Classroom 3 Toilet	3	Faucet	0286-C003-FA-02	27-Jul-24	6:43	H.Namiki	N.D.	0.010
Classroom 4 Water Fountain	4	Water Cooler	0286-C004-CO-01	27-Jul-24	6:44	H.Namiki	N.D.	0.010
Classroom 4 Girls Toilet	4	Faucet	0286-C004-FA-01	27-Jul-24	6:44	H.Namiki	N.D.	0.010
Classroom 4 Boys Toilet	4	Faucet	0286-C004-FA-02	27-Jul-24	6:44	H.Namiki	N.D.	0.010
		-Rema	inder of table left inten	tionally blan	k-			•

Building Nr . . 1. r / Fl Building 286 - Vouth Cont

[Notes]

QL: Quantitation Limit of Testing Lab

N.D.: Analyte Not Detected and if present below QL reported

Screening Level: 10ppb w/v set by CNIC (1 ppb w/v (ug/L) = 0.001 ppm w/v (mg/L);

Reference: Commander, Navy Installations Command Instruction (CNICINST) 5090.6A dated 8 July 2024

SAMPLE SUMMARY DATA SHEET (2/24)

Analyte: Lead / Test Method: EPA200.8 / Sample Matrix: Drinking Water

QL: 0.0005 mg/L

uilding Number / Floor :	Dunum	<u>, 274 - 1661 C</u>			Sampling	g		Screening
Room Name	Room #	Outlet Type	Sample ID#	Date	Time	Collected by	Results (mg/L)	Level (mg/L)
Kitchen Sink	N/A	Faucet	0294-0125-FA-01	27-Jul-24	6:48	H.Namiki	N.D.	0.010
Girls Bathroom Sink	N/A	Faucet	0294-0126-FA-01	27-Jul-24	6:48	H.Namiki	N.D.	0.010
Girls Bathroom Sink	N/A	Faucet	0294-0126-FA-02	27-Jul-24	6:48	H.Namiki	0.0009	0.010
Boys Bathroom Sink	N/A	Faucet	0294-0127-FA-01	27-Jul-24	6:48	H.Namiki	N.D.	0.010
Boys Bathroom Sink	N/A	Faucet	0294-0127-FA-02	27-Jul-24	6:48	H.Namiki	0.0006	0.010
Boys Bathroom Sink	N/A	Faucet	0294-0127-FA-03	27-Jul-24	6:48	H.Namiki	0.0010	0.010
Pink Room Girls Toilet	N/A	Faucet	0294-0101-FA-01	27-Jul-24	6:50	H.Namiki	0.0022	0.010
Blue Room Boys Toilet	N/A	Faucet	0294-0101-FA-02	27-Jul-24	6:50	H.Namiki	0.0025	0.010
Little Theater Toilet	N/A	Faucet	0294-0111-FA-01	27-Jul-24	6:52	H.Namiki	0.0022	0.010
Little Theater Toilet	N/A	Faucet	0294-0112-FA-01	27-Jul-24	6:52	H.Namiki	0.0016	0.010
		-Rema	inder of table left inten	tionally blan	k-			

[Notes]

QL: Quantitation Limit of Testing Lab

N.D.: Analyte Not Detected and if present below QL reported

Screening Level: 10ppb w/v set by CNIC (1 ppb w/v (ug/L) = 0.001 ppm w/v (mg/L);

Reference: Commander, Navy Installations Command Instruction (CNICINST) 5090.6A dated 8 July 2024

SAMPLE SUMMARY DATA SHEET (3/24)

Analyte: Lead / Test Method: EPA200.8 / Sample Matrix: Drinking Water

QL: 0.0005 mg/L

Building Number / Floor : Building 3250 - Child Development Center								Call No.2024-630D		
Room Name	Room #	Outlet Type	Sample ID#		Sampling	3	Results	Screening Level		
Koom Name	Κυσιπ π	Outlet Type		Date	Time	Collected by	(mg/L)	(mg/L)		
Isolation	104	Faucet	3250-0104-FA-01	27-Jul-24	6:28	H.Namiki	N.D.	0.010		
Toddler 1	126	Faucet	3250-0126-FA-01	27-Jul-24	6:23	H.Namiki	N.D.	0.010		
Toddler 1	126	Faucet	3250-0126-FA-02	27-Jul-24	6:23	H.Namiki	N.D.	0.010		
Toddler 1	126	Faucet	3250-0126-FA-03	27-Jul-24	6:23	H.Namiki	N.D.	0.010		
Toddler 1	126	Faucet	3250-0126-FA-04	27-Jul-24	6:23	H.Namiki	N.D.	0.010		
Toddler 1	126	Faucet	3250-0126-FA-05	27-Jul-24	6:23	H.Namiki	N.D.	0.010		
Cooler 1	121	Bubbler	3250-0121-CO-01	27-Jul-24	6:27	H.Namiki	N.D.	0.010		
Cooler 2	121	Bubbler	3250-0121-CO-02	27-Jul-24	6:27	H.Namiki	N.D.	0.010		
Toddler 2	121	Faucet	3250-0121-FA-01	27-Jul-24	6:21	H.Namiki	N.D.	0.010		
Toddler 2	121	Faucet	3250-0121-FA-02	27-Jul-24	6:21	H.Namiki	N.D.	0.010		
Toddler 2	121	Faucet	3250-0121-FA-03	27-Jul-24	6:21	H.Namiki	N.D.	0.010		
Toddler 2	121	Faucet	3250-0121-FA-04	27-Jul-24	6:21	H.Namiki	N.D.	0.010		
Toilet 1	127	Faucet	3250-0127-FA-01	27-Jul-24	6:28	H.Namiki	N.D.	0.010		
Toilet 1	127	Faucet	3250-0127-FA-02	27-Jul-24	6:24	H.Namiki	N.D.	0.010		
Staff Lounge and Toilet	134	Faucet	3250-0134-FA-01	27-Jul-24	6:19	H.Namiki	N.D.	0.010		
Staff Lounge and Toilet	134	Faucet	3250-0134-FA-02	27-Jul-24	6:19	H.Namiki	N.D.	0.010		
Staff Lounge and Toilet	134	Faucet	3250-0134-FA-03	27-Jul-24	6:19	H.Namiki	N.D.	0.010		
Infant 1	157	Faucet	3250-0157-FA-01	27-Jul-24	6:18	H.Namiki	0.0007	0.010		
Infant 1	157	Faucet	3250-0157-FA-02	27-Jul-24	6:18	H.Namiki	N.D.	0.010		
Infant 1	157	Faucet	3250-0157-FA-03	27-Jul-24	6:18	H.Namiki	0.0006	0.010		

Building 3250 - Child Dovelo Building Nu mbor / Flo ont Cont

[Notes]

QL: Quantitation Limit of Testing Lab

N.D.: Analyte Not Detected and if present below QL reported

Screening Level: 10ppb w/v set by CNIC (1 ppb w/v (ug/L) = 0.001 ppm w/v (mg/L);

Reference: Commander, Navy Installations Command Instruction (CNICINST) 5090.6A dated 8 July 2024

SAMPLE SUMMARY DATA SHEET (4/24)

Analyte: Lead / Test Method: EPA200.8 / Sample Matrix: Drinking Water

QL: 0.0005 mg/L

Building Number / Floor	: Building	g 3250 - Child	Development Cent	er	Sampling	a	Call No.2024-63	
Room Name	Room #	Outlet Type	Sample ID#	Date	Time	Collected	Results (mg/L)	Level (mg/L)
						by		
Infant 1	157	Faucet	3250-0157-FA-04	27-Jul-24	6:18	H.Namiki	N.D.	0.010
Infant 2	158	Faucet	3250-0158-FA-01	27-Jul-24	6:18	H.Namiki	N.D.	0.010
Infant 2	158	Faucet	3250-0158-FA-02	27-Jul-24	6:18	H.Namiki	N.D.	0.010
Infant 2	158	Faucet	3250-0158-FA-03	27-Jul-24	6:18	H.Namiki	0.0005	0.010
Toilet 2	105	Faucet	3250-0105-FA-01	27-Jul-24	6:29	H.Namiki	N.D.	0.010
Toilet 3	152	Faucet	3250-0152-FA-01	27-Jul-24	6:30	H.Namiki	N.D.	0.010
Kitchen	152	Faucet	3250-0152-FA-02	27-Jul-24	6:30	H.Namiki	0.0007	0.010
Kitchen	152	Faucet	3250-0152-FA-03	27-Jul-24	6:30	H.Namiki	0.0008	0.010
Kitchen	152	Faucet	3250-0152-FA-04	27-Jul-24	6:30	H.Namiki	N.D.	0.010
Kitchen	152	Faucet	3250-0152-FA-05	27-Jul-24	6:30	H.Namiki	N.D.	0.010
Part day Pre-School 3	139	Faucet	3250-0139-FA-01	27-Jul-24	6:33	H.Namiki	N.D.	0.010
Part day Pre-School 3	139	Faucet	3250-0139-FA-02	27-Jul-24	6:33	H.Namiki	0.0009	0.010
Cooler 3	Hallway 142	Cooler	3250-0142-CO-01	27-Jul-24	6:31	H.Namiki	0.047	0.010
Cooler 4	Hallway 142	Cooler	3250-0142-CO-02	27-Jul-24	6:31	H.Namiki	0.0051	0.010
Toddler 4	142	Faucet	3250-0142-FA-01	27-Jul-24	6:32	H.Namiki	N.D.	0.010
Toddler 4	142	Faucet	3250-0142-FA-02	27-Jul-24	6:32	H.Namiki	N.D.	0.010
Toddler 4	142	Faucet	3250-0142-FA-03	27-Jul-24	6:32	H.Namiki	N.D.	0.010
Part day pre-school 2	188	Faucet	3250-0188-FA-01	27-Jul-24	6:14	H.Namiki	N.D.	0.010
Part day pre-school 2	188	Faucet	3250-0188-FA-02	27-Jul-24	6:14	H.Namiki	N.D.	0.010
Part day pre-school 2	188	Faucet	3250-0188-FA-03	27-Jul-24	6:14	H.Namiki	N.D.	0.010

- 2250 Child Davel - ----D 111 nt Co - -(..... .

: Yellow-highlighted value(s) exceeded Screening Level.

[Notes]

QL: Quantitation Limit of Testing Lab

N.D.: Analyte Not Detected and if present below QL reported

Screening Level: 10ppb w/v set by CNIC (1 ppb w/v (ug/L) = 0.001 ppm w/v (mg/L);

Reference: Commander, Navy Installations Command Instruction (CNICINST) 5090.6A dated 8 July 2024

SAMPLE SUMMARY DATA SHEET (5/24)

Analyte: Lead / Test Method: EPA200.8 / Sample Matrix: Drinking Water

QL: 0.0005 mg/L

Building Number / Floor	: Buildinş	g 3250 - Child	Development Cente	er	C		Call No	5.2024-630D
Room Name	Room #	Outlet Type	Sample ID#	Data	Sampling	g Collected	Results (mg/L)	Screening Level
				Date	Time	by		(mg/L)
Part day pre-school 1	184	Faucet	3250-0184-FA-01	27-Jul-24	6:12	H.Namiki	N.D.	0.010
Part day pre-school 1	184	Faucet	3250-0184-FA-02	27-Jul-24	6:12	H.Namiki	N.D.	0.010
Outside	184	Faucet	3250-0184-FA-03	27-Jul-24	6:12	H.Namiki	0.0010	0.010
Outside	184	Faucet	3250-0184-FA-04	27-Jul-24	6:12	H.Namiki	N.D.	0.010
Infant 4	162	Faucet	3250-0162-FA-01	27-Jul-24	6:15	H.Namiki	0.0013	0.010
Infant 4	162	Faucet	3250-0162-FA-02	27-Jul-24	6:15	H.Namiki	0.0011	0.010
Infant 4	162	Bubbler	3250-0162-BU-01	27-Jul-24	6:13	H.Namiki	0.0011	0.010
Infant 3	161	Faucet	3250-0161-FA-01	27-Jul-24	6:13	H.Namiki	0.0010	0.010
Infant 3	161	Faucet	3250-0161-FA-02	27-Jul-24	6:13	H.Namiki	N.D.	0.010
Infant 3	161	Faucet	3250-0161-FA-03	27-Jul-24	6:13	H.Namiki	0.0007	0.010
Pre-Toddler 1	166	Faucet	3250-0166-FA-01	27-Jul-24	6:08	H.Namiki	N.D.	0.010
Pre-Toddler 1	166	Faucet	3250-0166-FA-02	27-Jul-24	6:08	H.Namiki	N.D.	0.010
Pre-Toddler 1	166	Faucet	3250-0166-FA-03	27-Jul-24	6:08	H.Namiki	N.D.	0.010
Pre-Toddler 1	166	Faucet	3250-0166-FA-04	27-Jul-24	6:08	H.Namiki	N.D.	0.010
Pre-Toddler 1	166	Faucet	3250-0166-FA-05	27-Jul-24	6:08	H.Namiki	N.D.	0.010
Pre-Toddler 1	166	Bubbler	3250-0166-BU-01	27-Jul-24	6:00	H.Namiki	N.D.	0.010
Pre-Toddler 2	167	Faucet	3250-0167-FA-01	27-Jul-24	6:07	H.Namiki	N.D.	0.010
Pre-Toddler 2	167	Faucet	3250-0167-FA-02	27-Jul-24	6:07	H.Namiki	N.D.	0.010
Pre-Toddler 2	167	Faucet	3250-0167-FA-03	27-Jul-24	6:07	H.Namiki	N.D.	0.010
Pre-Toddler 2	167	Faucet	3250-0167-FA-04	27-Jul-24	6:07	H.Namiki	N.D.	0.010

[Notes]

QL: Quantitation Limit of Testing Lab

N.D.: Analyte Not Detected and if present below QL reported

Screening Level: 10ppb w/v set by CNIC (1 ppb w/v (ug/L) = 0.001 ppm w/v (mg/L);

Reference: Commander, Navy Installations Command Instruction (CNICINST) 5090.6A dated 8 July 2024

SAMPLE SUMMARY DATA SHEET (6/24)

Analyte: Lead / Test Method: EPA200.8 / Sample Matrix: Drinking Water

QL: 0.0005 mg/L

iilding Number / Floo	r : Building	g 3250 - Child	Development Cento	er	Sampling	3		Screening
Room Name	Room #	Outlet Type	Sample ID#	Date	Time	Collected by	Results (mg/L)	Level (mg/L)
Pre-Toddler 2	167	Faucet	3250-0167-FA-05	27-Jul-24	6:07	H.Namiki	N.D.	0.010
Pre-Toddler 3	168	Faucet	3250-0168-FA-01	27-Jul-24	6:01	H.Namiki	0.0016	0.010
Pre-Toddler 3	168	Faucet	3250-0168-FA-02	27-Jul-24	6:02	H.Namiki	0.0008	0.010
Pre-Toddler 3	168	Faucet	3250-0168-FA-03	27-Jul-24	6:02	H.Namiki	N.D.	0.010
Pre-Toddler 3	168	Faucet	3250-0168-FA-04	27-Jul-24	6:02	H.Namiki	N.D.	0.010
Pre-Toddler 3	168	Faucet	3250-0168-FA-05	27-Jul-24	6:02	H.Namiki	0.0044	0.010
Pre-Toddler 4	169	Faucet	3250-0169-FA-01	27-Jul-24	5:58	H.Namiki	N.D.	0.010
Pre-Toddler 4	169	Faucet	3250-0169-FA-02	27-Jul-24	5:58	H.Namiki	N.D.	0.010
Pre-Toddler 4	169	Faucet	3250-0169-FA-03	27-Jul-24	5:59	H.Namiki	N.D.	0.010
Pre-Toddler 4	169	Faucet	3250-0169-FA-04	27-Jul-24	5:58	H.Namiki	0.0005	0.010
Pre-Toddler 4	169	Faucet	3250-0169-FA-05	27-Jul-24	5:58	H.Namiki	0.0041	0.010
Pre-school 4	183	Faucet	3250-0183-FA-01	27-Jul-24	6:09	H.Namiki	0.0012	0.010
Pre-school 4	183	Faucet	3250-0183-FA-02	27-Jul-24	6:10	H.Namiki	N.D.	0.010
Pre-school 4	183	Faucet	3250-0183-FA-03	27-Jul-24	6:10	H.Namiki	N.D.	0.010
Pre-school 3	178	Faucet	3250-0178-FA-01	27-Jul-24	6:11	H.Namiki	N.D.	0.010
Pre-school 3	178	Faucet	3250-0178-FA-02	27-Jul-24	6:11	H.Namiki	N.D.	0.010
Pre-school 3	178	Faucet	3250-0178-FA-03	27-Jul-24	6:11	H.Namiki	N.D.	0.010
Pre-school 2	177	Faucet	3250-0177-FA-01	27-Jul-24	6:04	H.Namiki	0.0006	0.010
Pre-school 2	177	Faucet	3250-0177-FA-02	27-Jul-24	6:05	H.Namiki	N.D.	0.010
Pre-school 2	177	Faucet	3250-0177-FA-03	27-Jul-24	6:05	H.Namiki	N.D.	0.010

Building 3250 - Child Dovelo Building Nr mbor / Fl ont Cont

[Notes]

QL: Quantitation Limit of Testing Lab

N.D.: Analyte Not Detected and if present below QL reported

Screening Level: 10ppb w/v set by CNIC (1 ppb w/v (ug/L) = 0.001 ppm w/v (mg/L);

Reference: Commander, Navy Installations Command Instruction (CNICINST) 5090.6A dated 8 July 2024

SAMPLE SUMMARY DATA SHEET (7/24)

Analyte: Lead / Test Method: EPA200.8 / Sample Matrix: Drinking Water

QL: 0.0005 mg/L

lding Number / Floo	or : Building	g 3250 - Child	Development Cente	er	Sampling	2		Screening
Room Name	Room #	Outlet Type	Sample ID#	Date	Time	Collected by	Results (mg/L)	Level (mg/L)
Cooler 5	177	Cooler	3250-0177-CO-01	27-Jul-24	6:05	H.Namiki	0.0031	0.010
Cooler 6	177	Cooler	3250-0177-CO-02	27-Jul-24	6:06	H.Namiki	0.0005	0.010
Pre-school 1	176	Faucet	3250-0176-FA-01	27-Jul-24	6:05	H.Namiki	0.0007	0.010
Pre-school 1	176	Faucet	3250-0176-FA-02	27-Jul-24	6:05	H.Namiki	0.0015	0.010
Pre-school 1	176	Faucet	3250-0176-FA-03	27-Jul-24	6:05	H.Namiki	0.0023	0.010
Youth Sport	117	Faucet	3250-0117-FA-01	27-Jul-24	6:23	H.Namiki	0.0009	0.010
Youth Sport	117	Faucet	3250-0117-FA-02	27-Jul-24	6:24	H.Namiki	0.0051	0.010
Youth Sport	117	Faucet	3250-0117-FA-03	27-Jul-24	6:24	H.Namiki	0.011	0.010
Youth Sport	117	Faucet	3250-0117-FA-04	27-Jul-24	6:24	H.Namiki	0.0073	0.010
Youth Sport	117	Faucet	3250-0117-FA-05	27-Jul-24	6:26	H.Namiki	0.0068	0.010
YSF Admin	113	Faucet	3250-0113-FA-01	27-Jul-24	6:26	H.Namiki	0.0007	0.010
YSF Admin	113	Faucet	3250-0113-FA-02	27-Jul-24	6:26	H.Namiki	N.D.	0.010
YSF Admin	113	Faucet	3250-0113-FA-03	27-Jul-24	6:26	H.Namiki	0.0007	0.010
YSF Admin	113	Faucet	3250-0113-FA-04	27-Jul-24	6:26	H.Namiki	0.0009	0.010
		-Rema	inder of table left inten	tionally blan	k-			•

: Yellow-highlighted value(s) exceeded Screening Level.

[Notes]

QL: Quantitation Limit of Testing Lab

N.D.: Analyte Not Detected and if present below QL reported

Screening Level: 10ppb w/v set by CNIC (1 ppb w/v (ug/L) = 0.001 ppm w/v (mg/L);

Reference: Commander, Navy Installations Command Instruction (CNICINST) 5090.6A dated 8 July 2024

Re-sampling Results

Contract No: N40084-20-D-0051

Chugai Technos Test Report

Call No.2024-761D

Sampling Location / Name: NAF Atsugi: DW Monitoring (LIPA resampling, AUGUST 2024)

NAF, ATSUGI, ENV

Report Issue Date:

11 Sep 2024

Chugai Technos Corporation

2-2-16 Ohnodai Midori-ku, Chiba 267-0056, Japan Tel: +81-43-295-1101 Fax: +81-43-295-2217 Kiyomi Noriyuki Manager

X. mought

SAMPLE SUMMARY DATA SHEET (1/4)

Analyte: Lead / Test Method: EPA200.8 / Sample Matrix: Drinking Water

QL: 0.0005 mg/L

Building Number / Floo	or : Building	g 3250 - Child	Development Cent	er			Call No.2024-761D		
Room Name	Room #	Outlet Type	Sample ID#		Samplin	g	Results	Screening Level	
Koom Name	Kuun #	Outlet Type	Sample ID#	Date	Time	Collected by	(mg/L)	(mg/L)	
Youth Sport	117	Faucet	3250-0117-FA-03-FD	27-Aug-24	8:39	S.Mizukami	0.0048	0.010	
Youth Sport	117	Faucet	3250-0117-FA-03-FF30	27-Aug-24	8:39	S.Mizukami	0.0005	0.010	
Cooler 3	Hallway 142	Cooler	3250-0142-CO-01-FF15	27-Aug-24	8:42	S.Mizukami	N.D.	0.010	
Cooler 3	Hallway 142	Cooler	3250-0142-CO-01-FD	27-Aug-24	8:43	S.Mizukami	N.D.	0.010	
Cooler 3	Hallway 142	Cooler	3250-0142-CO-01-FF30	27-Aug-24	8:43	S.Mizukami	N.D.	0.010	
	1	-Rema	inder of table left inten	tionally blan	k-				

N.D.: Analyte Not Detected and if present below QL reported

QL: Quantitation Limit of Testing Lab

[Notes]

Screening Level: 10ppb w/v set by CNIC (1 ppb w/v (ug/L) = 0.001 ppm w/v (mg/L);

Reference: Commander, Navy Installations Command Instruction (CNICINST) 5090.6A dated 8 July 2024

FLOOR PLANS OF CDC, YOUTH & TEEN CENTER

Enclosure (3)

Floor Plans of CDC, TC, YC

Enclosure (3)





