



DEPARTMENT OF THE NAVY
COMMANDER, FLEET ACTIVITIES YOKOSUKA
PSC 473 BOX 1
FPO AP 96349

5090
Ser N00/293
9 May 23

From: Commander, Fleet Activities Yokosuka
To: Parents and Staff

Subj: DRINKING WATER LEAD SAMPLING RESULTS AT YOKOSUKA DUNCAN
STREET CHILD DEVELOPMENT CENTER


Encl: (1) Sample Summary Results Table for Fleet Activities Yokosuka – Duncan Street Child
Development Center (Building 4300)

1. The Navy is committed to maintaining safe drinking water on its installations. Our drinking water distribution system is regularly tested for lead and is in compliance with the Environmental Protection Agency's (EPA) Lead and Copper Rule and the Safe Drinking Water Act.
2. Lead exposure is a particular concern for children. Lead in drinking water typically comes from the plumbing inside buildings including lead service lines, fittings, solder, water fountains/coolers, or water faucets. The Navy policy requires we test the lead content of drinking water in priority areas such as schools, youth centers (YCs), and child development centers (CDCs). Lead in Priority Areas (LIPA) testing was conducted at the Yokosuka Duncan Street Child Development Center (Bldg. 4300) on 1 April 2023.
3. I am pleased to report that all drinking water intended for consumption, to include drinking water and water intended for cooking or washing, is at or below the Navy lead screening level of 15 parts per billion.
4. Navy environmental personnel conducted this testing at the Yokosuka Duncan Street Child Development Center following Navy policy. Samples from various locations in the CDC were sent to a Navy Water Quality Oversight Council validated laboratory for analysis.
5. We also tested other sinks used for washing. These fixtures were also below screening levels for lead in schools and day care centers. In all, 91 samples were taken and tested.
6. A copy of all test results is enclosed for your information. You can also see a hard copy of our water testing results by contacting Duncan Street Child Development Center, which is open Monday to Friday (0600-1800).
 - a. To learn more about lead in drinking water in schools and day care centers visit the following EPA website: <https://www.epa.gov/ground-water-and-drinking-water/3ts-reducing-lead-drinking-water>

Subj: DRINKING WATER LEAD SAMPLING RESULTS AT YOKOSUKA DUNCAN STREET CHILD DEVELOPMENT CENTER

b. To learn more about the installations public water supplier, see the Fleet Activities Yokosuka annual water quality report: <https://cnrj.cnrc.navy.mil/Operations-and-Management/Water-Quality-Information/Water-quality-reports/#CFAY>

7. While lead in the drinking water at these facilities is below the Navy screening levels for schools and daycare centers, if you have any health related questions or concerns about lead exposure, you are encouraged to contact your health care provider or if you are a TRICARE beneficiary use the Yokosuka Naval Hospital central appointment line at DSN: 243-5352.



L. D. SOBOL

Sample Summary Results Table
Priority Areas Lead Testing (April 2023)
FLEACT Yokosuka - Duncan St. Child Development Center
Building: 4300

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION					INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS		CORRECTIVE ACTIONS	POST-CORRECTIVE ACTION SAMPLING RESULTS	
CATEGORY	SAMPLE ID	Room Number	Outlet Location	Outlet Description	Lead Screening Level of 15 ppb			Lead Screening Level of 15 ppb			Description	Recommended Level = 15 ppb
					First Draw (ppb)	Retest required?	Date Fixture Secured?	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb) (See note 2)		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE					4/1/2023			mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE					4/25/2023			mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
DRINKING	YSK4300B005	1	Preschool	Bubbler	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
DRINKING	YSK4300B011	2	Preschool	Bubbler	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
DRINKING	YSK4300C001	2	Lobby	Cooler	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
DRINKING	YSK4300C002	2	Lobby	Cooler	0.9	NO	N/A	N/A	N/A	N/A	N/A	N/A
DRINKING	YSK4300B083	4	Pre-Toddler	Bubbler	1.0	NO	N/A	N/A	N/A	N/A	N/A	N/A
DRINKING	YSK4300B086	5	Pre-Toddler	Bubbler	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
DRINKING	YSK4300B099	6	Toddler	Bubbler	1.5	NO	N/A	N/A	N/A	N/A	N/A	N/A
DRINKING	YSK4300B025	7	Toddler	Bubbler	3.8	NO	N/A	N/A	N/A	N/A	N/A	N/A
DRINKING	YSK4300B031	8	Pre-School	Bubbler	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
DRINKING	YSK4300B038	9	Shared Space	Bubbler	1.0	NO	N/A	N/A	N/A	N/A	N/A	N/A
DRINKING	YSK4300B060	Playground	Outside	Bubbler	8.2	NO	N/A	N/A	N/A	N/A	N/A	N/A
DRINKING	YSK4300B061	Playground	Outside	Bubbler	2.5	NO	N/A	N/A	N/A	N/A	N/A	N/A
DRINKING	YSK4300B062	Playground	Outside	Bubbler	1.8	NO	N/A	N/A	N/A	N/A	N/A	N/A
DRINKING	YSK4300B063	Playground	Outside	Bubbler	4.4	NO	N/A	N/A	N/A	N/A	N/A	N/A
COOKING	YSK4300F055	NA	Kitchen	Faucet	1.2	NO	N/A	N/A	N/A	N/A	N/A	N/A
COOKING	YSK4300F057	NA	Kitchen	Faucet	0.9	NO	N/A	N/A	N/A	N/A	N/A	N/A
COOKING	YSK4300F058	NA	Kitchen	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F006	1	Preschool	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F007	1	Preschool	Faucet	1.5	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F008	1	Preschool	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F009	1	Preschool (Art Room)	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F010	1	Preschool (Art Room)	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F012	2	Preschool	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F013	2	Preschool	Faucet	0.5	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F014	2	Preschool	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F015	2	Preschool (Art Room)	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F016	2	Preschool (Art Room)	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F075	3	Infant	Faucet	0.7	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F076	3	Infant	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F077	3	Infant (Bathroom)	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F093	5	Pre-Toddler (Bathroom)	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F032	8	Pre-School	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F033	8	Pre-School	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F034	8	Pre-School	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F035	8	Pre-School	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F036	8	Pre-School (Art Room)	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F037	8	Pre-School (Art Room)	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F039	9	Classroom	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F040	9	Classroom	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F041	9	Classroom	Faucet	0.98	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F042	9	Art Room	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F043	9	Art Room	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F017	34	Women's Bathroom	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F018	34	Women's Bathroom	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F019	34	Women's Bathroom	Faucet	1.0	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F020	35	Men's Bathroom	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F021	35	Men's Bathroom	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F073	36	Staff Room	Faucet	0.8	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F074	38	Bathroom in Staff Room	Faucet	0.7	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F045	10A	Infant	Faucet	2.0	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F046	10A	Infant	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F048	10A	Infant	Faucet	1.0	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F049	10A	Infant (Bathroom)	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F047	10B	Infant	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F050	11A	Infant	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F051	11A	Infant	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F053	11A	Infant	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F054	11A	Infant (Bathroom)	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F052	11B	Infant	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F078	4A	Pre-Toddler	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F079	4A	Pre-Toddler	Faucet	1.4	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F080	4A	Pre-Toddler	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A

Sample Summary Results Table
Priority Areas Lead Testing (April 2023)
FLEACT Yokosuka - Duncan St. Child Development Center
Building: 4300

SAMPLING LOCATION DESCRIPTION					INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS		CORRECTIVE ACTIONS	POST-CORRECTIVE ACTION SAMPLING RESULTS	
CATEGORY	SAMPLE ID	Room Number	Outlet Location	Outlet Description	Lead Screening Level of 15 ppb			Lead Screening Level of 15 ppb			Description	Recommended Level = 15 ppb
					First Draw (ppb)	Retest required?	Date Fixture Secured?	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb) (See note 2)		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE					4/1/2023			mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE					4/25/2023			mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
WASHING	YSK4300F081	4A	Pre-Toddler (Art room)	Faucet	0.6	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F082	4A	Pre-Toddler (Art room)	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F084	4B	Pre-Toddler	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F085	4B	Pre-Toddler	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F087	5A	Pre-Toddler	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F088	5B	Pre-Toddler	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F089	5B	Pre-Toddler	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F090	5B	Pre-Toddler	Faucet	6.5	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F091	5B	Pre-Toddler	Faucet	1.8	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F092	5B	Pre-Toddler	Faucet	3.9	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F094	6A	Toddler	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F095	6A	Toddler	Faucet	0.8	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F096	6A	Toddler	Faucet	1.4	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F097	6A	Toddler (Art Room)	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F098	6A	Toddler (Art Room)	Faucet	0.5	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F100	6B	Toddler	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F101	6B	Toddler	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F102	6B	Toddler	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F022	7A	Toddler	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F023	7A	Toddler	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F024	7A	Toddler	Faucet	1.0	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F026	7B	Toddler	Faucet	0.6	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F027	7B	Toddler	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F028	7B	Toddler	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F029	7B	Toddler (Art Room)	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F030	7B	Toddler (Art Room)	Faucet	Not Detected	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F004	NA	Isolation Room	Faucet	3.3	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F044	NA	Bathroom (Storage) next to Infant Room (10)	Faucet	0.6	NO	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	YSK4300F059	NA	Bathroom next to Kitchen	Faucet	0.5	NO	N/A	N/A	N/A	N/A	N/A	N/A

Notes:

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST-CORRECTIVE ACTION RESULTS
	Lead Screening Level of 15 ppb				
	First Draw (ppb)	Water Fountain	First Draw (ppb)	Follow up Flush	First Draw (ppb)
Total Drinking	14	0	0	0	0
Total Drinking > 15 ppb	0	0	0	0	0
Total Cooking	3	0	0	0	0
Total Cooking > 15 ppb	0	0	0	0	0
Total Washing	74	0	0	0	0
Total Washing > 15 ppb	0	0	0	0	0
Total Samples	91	0	0	0	0
Total Samples > 15 ppb	0	0	0	0	0