



Consumer Confidence Report 2024

U.S. Naval Air Facility Misawa Drinking Water System



DFSP Hachinohe, Japan


Issued in accordance with Commander, Navy Installations Command Instruction 5090.1B, N4, 15 Mar 2021.
This report reflects monitoring data collected in 2024 and will be updated annually.

U.S. Naval Air Facility Misawa is pleased to provide you with this annual report on drinking water quality for Defense Fuel Support Point (DFSP) Hachinohe. This report provides information about the water delivered to DFSP Hachinohe in 2024. It describes where our water comes from, what it contains, and how it compares to standards set by the U.S. Navy's Overseas Drinking Water Program and the Japanese Environmental Governing Standards.

Source of Water

Drinking water at DFSP Hachinohe is purchased from the Hachinohe Regional Water Supply Authority (HRWSA), which owns and operates the Hakusan Water Treatment Plant (HWTP). HWTP treats surface water from the Mabechi River and the Niida River with conventional treatment and chlorine disinfection processes. In 2019, HWTP was visited by the Navy Water Quality Oversight Council. A schematic of the HRWSA system serving DFSP Hachinohe is shown below.

Water Distribution System



Water distribution networks at the three DFSP Hachinohe pump stations are administratively managed together as one water distribution system because all three stations receive treated water from the same source. The U.S. Naval Air Facility (U.S. NAF) Misawa Public Works Department (PWD) operates the water distribution system within the bounds of DFSP Hachinohe and manages compliance actions with all water quality requirements.

Compliance with Drinking Water Requirements

U.S. military installations overseas are required to meet all criteria established in the latest Japan Environmental Governing Standards (JEGS), which are intended to ensure DoD activities and installations in Japan protect human health and the environment through specific environmental compliance criteria.

Navy installations are required to meet or exceed U.S. National Primary Drinking Water regulations, under the Safe Drinking Water Act of 1974, to ensure overseas drinking water systems meet the same water quality as required in the U.S. These standards require monitoring and testing of the drinking water for contaminants on a regular basis to ensure it is safe to drink. PWD regularly conducts environmental audits to verify compliance, and a Sanitary Survey (SS) is conducted every three years by an external team. During the SS conducted in May 2023, 13 deficiencies were identified; however, 11 of the deficiencies were resolved, and only 2 (1 significant) remain to be resolved. As a result, the Regional Water Quality Board granted DFSP Hachinohe a Conditional Certificate To Operate (CTO). A full CTO will be awarded when closure of the remaining significant deficiency is achieved.

Surface Water Treatment Rule

Surface water is a common source of water within the United States and the rest of the world. As a Japanese water authority, HWTP is not required to adhere to the American water regulations and standards for surface water. However, this does not mean that the water is not safe to drink. NAF Misawa PWD monitors the drinking water received from HWTP to ensure that DFSP Hachinohe is meeting the required American water regulations and standards. In 2023, NAF Misawa PWD started work with Naval Facilities Engineering Systems Command (NAVFAC) Pacific (PAC) in the development of a compliance plan to demonstrate that the Japanese water authority, HWTP, uses a host of high technological and effective treatment methods that either meet or surpass the required treatment techniques of an American water authority. The compliance plan is projected to be completed in early 2025 and requires the approval of Commander Navy Installations Command (CNIC) subject matter experts to ensure that the Japanese water authority is complying with the surface water treatment rule (SWTR).

Important Health Information

Some individuals may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised people, such as those undergoing chemotherapy, those who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, the elderly, and infants can be particularly at risk from infections. These individuals should seek advice about drinking water from their health care providers. The U.S. Environmental Protection Agency (EPA) and the Center for Disease Control and Prevention have established guidelines on the appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants. This information can be obtained by calling the EPA Safe Drinking Water Hotline at 1-800-426-4791.

Possible Source Contaminants

The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA Safe Drinking Water Hotline at 1-800-426-4791 or visiting the EPA website at

<https://www.epa.gov/dwstandardsregulations/drinking-water-contaminant-human-health-effects-information>

As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material. It can also pick up other contaminants resulting from the presence of animals or human activity. Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production. They can also come from gas stations, urban stormwater runoff, and septic systems.
- **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.

The U.S. Environmental Protection Agency (EPA) established a three tier public notification plan for drinking water, which is summarized in Table 1 below. We follow this outline to ensure that you are notified in a timely manner if notifications are necessary.

Table 1. The 3 Tiers of Public Notification*		
	Required Distribution Time	Required Distribution Time
Tier 1: Immediate Notice	Any time a situation occurs where there is the potential for human health to be immediately impacted, water suppliers have 24 hours to notify people who may drink the water of the situation.	Should a Tier 1 notification be necessary, we will notify you via an All Hands E-mail message and Facebook.
Tier 2: Notice as Soon as Possible	Any time a water system provides water with levels of a contaminant that exceed EPA or state standards or that hasn't been treated properly, but that doesn't pose an immediate risk to human health, the water system must notify its customers as soon as possible, but within 30 days of the violation.	We will notify you of a Tier 2 concern through an All Hands E-mail message and Facebook.
Tier 3: Annual Notice	When water systems violate a drinking water standard that does not have a direct impact on human health (For Example, failing to take a required sample on time) the water supplier has up to a year to provide a notice of this situation to its customers.	Tier 3 notifications are published annually in this document, the Consumer Confidence Report.

*Definitions taken from EPA website.

See <http://water.epa.gov/lawsregs/rulesregs/sdwa/publicnotification/basicinformation.cfm> for more information.

Other Potential Contaminants

Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. When your water has been sitting for several hours, you can further minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using the water for drinking or cooking. Drinking water samples are collected from consumer taps including family housing units to analyze for lead annually. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>

Disinfection By Products

Chlorine or other chemicals are added to drinking water during the treatment process to disinfect it from microbial contaminants such as viruses and bacteria. These chemicals also react with dissolved organic matter to produce chemical byproducts that may be harmful. As with other contaminants, these are carefully monitored to ensure consumer health.

Per- and Polyfluoroalkyl Substances

What are per- and polyfluoroalkyl substances and where do they come from?

Per- and polyfluoroalkyl substances (PFAS) are a group of thousands of man-made chemicals. PFAS have been used in a variety of industries and consumer products around the globe, including in the U.S., since the 1940s. PFAS are found in many consumer products, as well as in industrial products, like certain firefighting agents called aqueous film forming foam (AFFF). PFAS is also found in essential use applications such as in microelectronics, batteries, and medical equipment. PFAS chemicals are persistent in the environment, and some are persistent in the human body – meaning they do not break down and they can accumulate over time.

Is there a regulation for PFAS in drinking water?

On April 26, 2024, the United States Environmental Protection Agency (EPA) published a National Primary Drinking Water Regulation (NPDWR) final rule on drinking water standards for six PFAS under the Safe Drinking Water Act (SDWA). The rule establishes the following maximum contaminant levels (MCLs):

- perfluorooctane sulfonic acid (PFOS) = 4 ppt
- perfluorooctanoic acid (PFOA) = 4 ppt
- hexafluoropropylene oxide dimer acid (HFPO-DA, commonly known as GenX) = 10 ppt
- perfluorononanoic acid (PFNA) = 10 ppt
- perfluorohexane sulfonic acid (PFHxS) = 10 ppt
- HI MCL for PFHxS, PFNA, perfluorobutane sulfonic acid (PFBS), and GenX = 1 (unitless).

Under the NPDWR, regulated public water systems (PWS) are required to complete initial monitoring by April 26, 2027. Beginning April 26, 2027, regulated PWSs will conduct ongoing compliance monitoring in accordance with the frequency dictated by the rule and as determined by the initial compliance monitoring results. Regulated PWSs must demonstrate compliance with the Maximum Contaminant Levels (MCLs) by April 26, 2029.

In order to provide safe drinking water to all Department of Defense (DoD) personnel, OSD policy extends this requirement to all DoD systems which provide drinking water for human consumption, regardless of size of the drinking water system. In addition to the six regulated compounds, DoD-owned systems are required by DoD policy to monitor for all 25 compounds detected when using EPA Method 533.

Protecting the health of our personnel, their families, and the communities in which we serve is a priority for the Department. DoD is committed to complying with requirements of the NPDWR and the continued provision of safe drinking water to those that work and live on DoD installations.

Has NAF Misawa, DFSP Hachinohe tested its water for PFAS in 2024?

Yes. In November, 2024 samples were collected from Bldg. 6100104.

PFAS Below MRL

We are pleased to report that drinking water testing results for all 25 PFAS covered by the sampling method, including the six regulated PFAS, were not detected in your water system.

What is next?

NAF Misawa, DFSP Hachinohe will continue to monitor for PFAS in accordance with the EPA regulation and DoD policy. Once required initial monitoring information is available, we will calculate the Running Annual Averages (RAA) for the regulated PFAS and will compare those numbers to the MCL and Hazard Index (HI) trigger levels. This will determine what our continuing monitoring requirements will be beginning in 2027, and if needed, we will plan operational or infrastructure changes to ensure our water complies with the PFAS MCLs and HI by April 2029 in accordance with the SDWA.

Drinking Water Monitoring

PWD Misawa uses Japanese and EPA approved laboratory methods to analyze our drinking water, and monitors drinking water for the following constituents. Table 2 lists the contaminant and required sampling frequency.

Table 2: Monitoring Frequency	
Constituent	Frequency
Coliform Bacteria, pH, Chlorine, Temperature	Monthly
Nitrate, Nitrite, Total Nitrate and Nitrite	Quarterly
PFAS	Quarterly until RAA Analysis Completed
Inorganic Chemicals, Volatile Organic Chemicals, Disinfection Byproducts, Pesticides/PCBs	Annually
Lead and Copper	Triennial
Radionuclides	Once every three years for gross alpha activity, and once every nine year for gross beta particles and photon radioactivity
Asbestos	Once every nine years

Water Quality Data

The following section lists constituents detected during the latest round of required sampling. Only those constituents detected are listed in Table 3. The presence of a contaminant does not necessarily indicate the water poses a health risk. As such, DFSP Hachinohe drinking water is safe and fit for human consumption.

Table 3: Detected Constituents in Drinking Water					
Inorganic Chemicals					
Contaminant and Unit	Range	MCL	MRDL	Violation	Typical Sources of Contaminants
Barium (ppm)	0.022	2	NA	No	Erosion of natural deposits
Nitrate (ppm)	0.95 - 1.4	10	NA	No	Runoff from fertilizer use; leaking from septic tanks, sewage, erosion of natural deposits
Sodium (ppm)	8.1	None	NA	No	Salt present in the water that is generally naturally occurring
Disinfectant/Disinfection Byproducts					
Contaminant and Unit	Range	MCL	MRDL	Violation	Typical Sources of Contaminants
Residual Chlorine (ppm)	0.31-0.68	4	4*	No**	Disinfectant water additive to control microbes
Total Trihalomethanes (ppm)	0.016-0.023	0.08	NA	No	By-product of chlorination
Halo Acetic Acids [HAA5] (ppm)	0.0094-0.011	0.06	NA	No	By-product of chlorination
Lead and Copper (2023 Data)					
Contaminant and Unit	90 th Percentile	AL	Samples > AL	Violation	Typical Sources of Contaminants
Copper (ppm)	0.0037	1.3	0	No	Corrosion of household plumbing system, erosion of natural deposits
Lead (ppm)	0.0	0.015	0	No	Corrosion of household plumbing system, erosion of natural deposits

Radionuclide					
Contaminant and Unit	Range	MCL	MRDL	Violation	Typical Sources of Contaminants
Gross Alpha (pCi/L)	1.97±0.533	15	NA	No	Erosion of natural deposits
Combined Radium -226 and -228	1.97±0.931	5	NA	No	Erosion of natural deposits

Notes:

*Residual Chlorine - Maximum Residual Disinfectant Level.

**Chlorine residual should be maintained at a minimum of 0.2 ppm to ensure against bacteriological growth in the distribution system. No bacteria has ever been detected in the drinking water.

Abbreviations and Definitions

AL: Action Level. The concentration of a contaminant in water that establishes the appropriate treatment for a water system. AL is based on a 90th percentile value.

MCL: Maximum Contaminant Level. The highest level of a contaminant allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG: Maximum Contaminant Level Goal. The level of contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MRDL: Maximum Residual Disinfectant Level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG: Maximum Residual Disinfection Level Goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NA: Not applicable.

ND: Not Detected.


ppm: parts per million, or milligrams per liter (mg/L).

ppb: parts per billion, or micrograms per liter (µg/L).

ppt: parts per trillion, or nanograms per liter (ng/L).

TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.

90th percentile: Represents the highest value found out of 90 percent of the samples taken. If the 90th percentile value is greater than the AL, a treatment evaluation and/or mitigation actions must be conducted on the water system.



Cross-connection and Backflow Prevention

Did you know that any connection between a public drinking water system and a separate source of questionable quality is considered a cross-connection?

For example, an ordinary garden hose submerged in a bucket of water, car radiator, or swimming pool can result in backflow contamination. To protect our water supply, a simple screw-on vacuum breaker must always be attached to the faucet when a garden hose is used.

Vacuum Breaker



Frequently Asked Questions

Why is this Consumer Confidence Report needed?

Each U.S. Navy overseas installation is required to provide its customers with a water quality report also known as a Consumer Confidence Report. This report is a general overview of the water quality delivered by your drinking water system. This report lists the regulated contaminants detected in the treated water and the level at which they were found for the preceding calendar year. Any exceedances of applicable regulations or guidance will be reported.

Why does the water sometimes look rusty?

Rusty or reddish tinted water may occur when a sudden change in pressure in the water distribution system causes rust in the distribution pipes to become dislodged. Iron causes the discoloration and is not a health risk. If the water looks rusty, flush your tap for three minutes, or until clear, before using the water. If hot tap water is rusty, the water heater may need to be flushed.

I don't like the taste/smell/appearance of my tap water. What is wrong with it?

Even when water meets standards, you may still object to its taste, smell, or appearance. Taste, smell, and appearance are aesthetic characteristics and do not pose health risks. Common complaints about water aesthetics include temporary cloudiness (typically caused by air bubbles) or chlorine taste (which can be improved by letting the water stand exposed to the air). If you want to improve the taste, smell, and appearance of your water, you can install a home water filter. Please keep in mind that filters require regular maintenance and replacement, and if ignored, these aesthetic characteristics may return.

Monitoring Violations

In December 2023, we became aware that our system was receiving water from Hakusan Water Treatment Plant containing levels of turbidity above 0.3 nephelometric turbidity unit (NTU) during the monthly data collection of the in-line turbidity monitoring system. The number of sample readings above 0.3 NTU had exceeded more than 5 percent of the total allowable monthly samples, as per the JEGS.

Data collection requirements were weekly to monitor the turbidity levels. There were no exceedances of the MCL of 5 NTU. The drinking water was safe and fit for human consumption. Our drinking water data collection requirements for turbidity were weekly until the turbidity levels reduce to levels prior to December 2023. Additional mitigations were in development if turbidity levels did not return to normalcy of 0.038 – 0.042 NTU.

This exceedance of more than 5 percent of total allowable monthly samples, as per the JEGS had continued through till June 2024. During the months of January, March, April and May, the sampling data reported exceedances and public notifications were provided to DFSP Hachinohe. In June 2024, the turbidity in-line monitor went through its annual maintenance. Upon completion of the annual maintenance, a drop in turbidity levels were noticed within the collected data.

Weekly monitoring continued through June 2024. In July 2024, turbidity level monitoring was updated to be bi-weekly until further verification that no additional exceedances were to occur. In August 2024, turbidity level monitoring returned to a monthly occurrence as prior to the initial December 2023 exceedance.

The maintenance contract for the in-line turbidity monitor was updated to ensure that the equipment receives maintenance bi-annually.

Public Participation Opportunities and Contacts

The Installation Commanding Officer has established an Installation Water Quality Board tasked with ensuring there is a reliable supply of drinking water for all people using DFSP Hachinohe facilities.

Please contact the NAF Misawa Public Affairs Office at DSN 226-4363 or the NAF Misawa Environmental Division at DSN 226-2497 for questions on drinking water in general.

Notice of Failure to Develop Initial Inventory of Drinking Water Service Lines

From: U.S. Naval Air Facility Misawa

To: Defense Fuel Support Point Hachinohe Drinking Water Consumer

Subj: Notice of Failure to Develop Initial Inventory of Drinking Water Service Lines

1. Our public water system is focused on protecting the health of every person working in our facilities on our installation. This notice contains important information about your drinking water. Please share this information with anyone who consumes water (drinking, showering, bathing, dishwashing, cooking, oral hygiene) at this location.

2. We were required to develop and make publicly available an initial inventory of service lines connected to our distribution system by October 16, 2024. Our system failed to submit this initial inventory of service lines to Commander, Navy Installations Command (CNIC). The inventory must identify the service line materials as galvanized, lead, non-lead or unknown. We are working diligently to identify and ultimately remove lead and galvanized service lines as soon as possible. This an important way to protect public health.

3. Because your service line material is unknown, there is the potential that some or all of the service line could be made of lead or galvanized pipe that was previously connected to lead.

4. Galvanized service lines that have adsorbed lead can contribute to lead in drinking water.

5. U.S. Naval Air Facility Misawa, Defense Fuel Support Point Hachinohe current water quality is in compliance with U.S. Environmental Protection Agency (EPA) lead and copper rule action levels, but we are committed to further investigation to determine if these lines require replacement.

6. If you have questions concerning any of the information provided in this notice, or if you have information that could help us better describe your service line, contact us via: 226-2497.

7. **Health effects of lead:** Exposure to lead in drinking water can cause serious health effects in all age groups. Infants and children can have decreases in IQ and attention span. Lead exposure can lead to new learning and behavior problems or worsen existing learning and behavior problems. The children of women who are exposed to lead before or during pregnancy can have an increased risk of these negative health effects. Adults can have increased risks of heart disease, high blood pressure, and kidney, or nervous system problems.

8. **Steps you can take to reduce lead in drinking water:** Below are recommended actions that you may take, separately or in combination, if you are concerned about lead in your drinking water. The list also includes where you may find more information and is not intended to be a complete list or to imply that all actions equally reduce lead in drinking water.

- a) ***Use your filter properly.*** Using a filter can reduce lead in drinking water. If you use a filter, it should be certified to remove lead. Read any directions provided with the filter to

learn how to properly install, maintain, and use your cartridge and when to replace it. Using the cartridge after it has expired can make it less effective at removing lead. Do not run hot water through the filter. For more information on facts and advice on home water filtration systems, visit EPA's website at <https://www.epa.gov/water-research/consumer-tool-identifying-point-use-and-pitcher-filters-certified-reduce-lead>.

- b) **Clean your aerator.** Regularly remove and clean your faucet's screen (also known as an aerator). Sediment, debris, and lead particles can collect in your aerator. If lead particles are caught in the aerator, lead can get into your water.
- c) **Use cold water.** Do not use hot water from the tap for drinking, cooking, or making baby formula as lead dissolves more easily into hot water. Boiling water does not remove lead from water.
- d) **Run your water.** The more time water has been sitting in pipes the more lead it may contain. Before drinking, flush your home's pipes by running the tap, taking a shower, doing laundry, or doing a load of dishes. The amount of time to run the water will depend on whether your home has a lead service line or not, as well as the length and diameter of the service line and the amount of plumbing in your home. It is recommended to flush for at least 3 to 5 minutes before using water for drinking or cooking, especially if the water hasn't been used for several hours. For water that has been sitting overnight, flushing for 5 minutes or longer is advisable.

9. **Get your child tested to determine lead levels in their blood.** If you have any health-related questions or concerns about lead exposure or a blood lead test, you are encouraged to contact your health care provider, or if you are a TRICARE beneficiary, use the REGION Appointment Center to schedule an appointment with your primary care provider at 226-6111.

The Centers for Disease Control and Prevention and the Navy recommend public health actions when the level of lead in a child's blood is 3.5 micrograms per deciliter (µg/dL) or more. For more information and links to the CDC's website, please visit <https://www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water>.

10. For more information on reducing lead exposure from your drinking water and the health effects of lead, visit EPA's website at <http://www.epa.gov/lead>.

To learn more about the quality of the drinking water on this installation, visit our Annual Consumer Confidence Water Quality Report at: <https://cnrj.cnmc.navy.mil/Operations-and-Management/Water-Quality-Information/Water-quality-reports/#NAFMisawa>.